# Emergency Checklist: Earthquake

Earthquakes cannot be prevented or predicted with any certainty. And, the cost associated with earthquake-triggered damage to buildings and property can be extraordinarily high. While this rare natural hazard cannot be eliminated, you can take preventive action that can greatly reduce the amount of damage sustained in the event of major earth movement. This involves advance planning, proper design and protection of buildings, and training of employees.

This checklist helps you identify property loss prevention measures you can take before and after an earthquake to help minimize the disruption it can cause to your facility.

For assistance in evaluating your exposures, developing appropriate design criteria and establishing an emergency response team, contact your local FM Global engineer or client service team.

# Before an Earthquake Strikes

# General

Determine the seismic risk to your facility by knowing these details:

- Probability and expected intensity of an earthquake at your site
- Stability of site soil (for example, is it soft, liquefiable, subject to lateral spreading or fault rupture?)
- Presence of secondary or complicating natural hazard exposures, such as tsunami, landslide, flood or severe weather

Establish a comprehensive emergency action plan to control hazards, ensure the integrity of fire protection, conduct salvage and repair operations, and minimize business interruption.

Provide and train an emergency response team (ERT) covering all shifts to implement the emergency action plan and stockpile emergency supplies that may be needed to support the ERT (see *The Emergency Response Team* [P8116]).

Ensure emergency gear such as tools, firefighting equipment and electrical generators are accessible and adequate.

Conduct recorded inspections and tests, as appropriate, of all seismic protection devices every five years.





#### **Protection from Earthquake Forces**

Determine the structural integrity of existing buildings and other structures.

Determine the loss exposure to contents due to overturning (toppling), sliding, swinging or rupture of:

- Items that pose a threat of ensuing fire
- Fire protection systems
- Critical building and production support equipment, production machinery and contents

For acquisitions and new construction, establish minimum seismic design criteria.

Implement an anchorage/bracing policy whenever equipment and piping is installed or relocated.

For design issues, engage qualified engineering consultants specializing in earthquake evaluation and rehabilitation.

### **Protection from Ensuing Fire**

Control fire hazards: Historically, fire has been a major secondary effect of earthquake. Fortunately, the hazard is lower today because of less vulnerable construction and the presence of more automatic fire suppression. The risk, however, is still present. Typical ways to reduce the fire threat include:

- Seismic shutoff valves on the main natural gas service line to each building
- Automatic shutoff valves for flammable liquid/gas distribution systems
- Engineered anchorage of floor-supported, gas-fired equipment
- Four-way restraint on suspended gas-fired equipment (space and radiant heaters, etc.)
- Engineered anchorage of gas-fired rooftop equipment
- Flexible gas connections between gas-fired equipment and piping to accommodate differential movement
- Retaining straps on C-clamp attachments and replacement of powder-driven fasteners used in hanger assemblies
- Bracing, flexibility and clearance on piping that transfers flammable liquid and gas
- Engineered restraint for tanks, storage cabinets and equipment utilizing flammable liquid
- Correction of deficiencies that could result in electrical arcing near combustible material
- Upper and lower restraint of high-pressure flammable and oxidizing gas cylinders to prevent toppling and "kicking out"

Protect your fire protection systems: Severe ground-shaking often damages automatic sprinkler systems with inadequate earthquake protection, resulting in water damage and impairment of the system at the very time it is needed most. This risk can be minimized by following provisions in FM Global Property Loss Prevention Data Sheet 2-8, *Earthquake Protection for Water-Based Fire Protection Systems*. Here are some of the most important measures:

- Brace the sprinkler piping (risers, mains, large branch lines); do not use U-bolt hangers as seismic braces.
- Provide flexibility on piping that spans between two structures that can move in different directions.
- Provide clearance where sprinkler piping passes through nonfrangible walls or floors.
- Protect sprinkler heads from damage with clearance, vertical restraint on branch lines, and splay wire bracing and compression struts on suspended ceiling systems.

- Provide retaining straps on C-clamps and replace powder-driven fasteners, if used in hanger assemblies.
- Anchor water-supply equipment, such as suction tanks, fire pumps and drivers, controllers, starter batteries, fuel tanks and emergency generators for electric fire pumps.
- Anchor storage racks with in-rack sprinklers and repair any rack damage immediately (for example, damage from forklift impact).
- Provide redundant water supplies for critical facilities.

### To Prevent Overturning

Prioritize the need for restraint, based on whether movement would result in fire, other hazardous conditions or significant loss. Consider the equipment's value, vulnerability, importance to production continuity, location and height-to-base ratio. Remember:

- Tall narrow objects are most prone to overturning, especially when mass is concentrated near the top.
- Forces can be amplified in the structure; items at the top of the building are more likely to overturn than items at grade level.

To mitigate overturning for high-priority items:

- Anchor the item to the floor or adjacent wall.
- Improve stability by grouping items together and bolting or bracing them to each other.
- Move heavier items to lower storage shelves.

## To Prevent Sliding or Swinging

Prioritize the need for restraint, applying the same criteria used above in "To Prevent Overturning."

- Tabletop equipment and unanchored low-profile production equipment or utilities such as boilers, generators, transformers and HVAC units may be subject to sliding.
- Common items subject to excessive swinging include suspended ceilings, space heaters, piping and electrical bus ducts.

To protect high-priority items from damage caused by sliding or swinging:

- Anchor floor-supported items to the floor or adjacent wall.
- Brace suspended items to the structure from which they are suspended.
- Install restraining devices at the edge of shelving or tables to prevent items from falling.
- Restrain suspended lighting fixtures in warehouses if they can impact adjacent items, causing damage to the fixture and allowing components to fall on storage below.

#### **To Minimize Rupture Concerns**

Identify rigid items that are vulnerable to rupture, such as process piping and tanks, utility conduits or any piping where breakage would result in extended interruption of production.

Restrain equipment with attached utilities to prevent overturning, sliding and excessive swinging.

For vulnerable piping or conduits, introduce the following improvements:

Sway bracing

 Retaining straps for C-clamp attachments and replacement of powder-driven fasteners used in hanger assemblies

- Clearance around pipes and conduits that pass through non-frangible walls and floors
- Flexibility where needed, using swing joints and flexible couplings
- Welded connections in piping systems whenever possible
- Seismically activated automatic shutoff valves for hazardous liquid and gas distribution systems
- Common foundations to support interconnected equipment
- Trenches or dikes of adequate capacity where liquid might be released from ruptured tanks

### After an Earthquake Strikes

Empower ERT members to maintain as much fire protection in service as possible when sprinkler piping is damaged.

Check that all sprinkler water supply valves are open and water supply is in service.

Repair damaged fire protection systems immediately. If system is impaired, follow FM Global's *Red Tag Permit System Wall Hanger* (P7427).

Check process system and gas, water and electrical services for damage.Shut off as necessary.

Prohibit hot work until fire protection is restored. For any repair that requires hot work, use and follow the instructions outlined in FM Global's *Hot Work Permit System Wall Hanger* (P9311).

Conduct salvage operations with awareness that fire danger is greater shortly after an earthquake.



P9807 © 2004, 2006 FM Global (Rev 11/2015) All rights reserved. fmglobal.com

FM Insurance Company Limited 1 Windsor Dials, Windsor, Berkshire, SL4 1RS Authorized by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority.

#### Contact Us:

To report an impairment or to find an FM Global office nearest you, visit fmglobal.com/contact.

#### Report a Loss:

Dial (1)877 NEW LOSS (639 5677)\* to report a property or cargo loss 24 hours a day, seven days a week. Or, to contact your client service team or designated claims office directly, go to fmglobal.com/claims or affiliatedfm.com/claims for location and contact information.

\*For clients of FM Global and AFM in Canada and the United States only.

#### Product Ordering Information:

For additional copies of this publication or other FM Global resources, order online 24 hours a day, seven days a week at fmglobalcatalog.com.

Or, for personal assistance worldwide, contact our U.S.-based customer services team, Monday – Friday, 8 a.m. – 5 p.m. ET:

- Toll-free: (1)877 364 6726 (Canada and the United States)
- Phone: +1 (1)401 477 7744
- Fax: +1 (1)401 477 7010
- E-mail: customerservices@fmglobal.com